

UQGS.S36448 - Heat-automatic Fire Detectors

Heat-automatic Fire Detectors

TRIGA Life Safety Systems L L C

7600 Olde Eight Rd.

Hudson, OH 44236 United States

S36448

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
TR-FIRE-CO-W (a)(b), TR-FIRE-CO-IV (a)(b), TR-PTIR-W (a), TR-PTIR-IV (a)	FT	D2	-	135	50	25
TR-HEAT-HT-W, TR-HEAT-HT-IV	FT	D1	-	190	50	25
TR-HEAT-ROR-W, TR-HEAT-ROR-IV	FT/ROR	D1	-	135	50	25
TR-HEAT-W, TR-HEAT-IV	FT	D1	-	135	50	25
TR-PHOTO-T-IV (a), TR-PHOTO-T-W (a)	FT	D1	-	135	50	25
TRW-HEAT	FT	D1	-	135	50	25
TRW-HEAT-ROR	FT/ROR	D1	-	135	50	25

Base Model	Related Detector	Control Unit Compatibility Restrictions
TRW-B210W	TRW-ACCLIMATE,, TRW-HEAT, TRW-HEAT-ROR	B2
TRW-B501W	TRW-ACCLIMATE,, TRW-HEAT, TRW-HEAT-ROR	B2

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

(a) - Complimentary listed to the 7th edition of UL 268 (UROX).

(b) - Complimentary listed to UL 2075 (FTAM) as a Carbon Monoxide (CO) detector.

Last Updated on 2021-05-28

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"